


2017 GlobalShop
March 2017
Mandalay Bay, Las Vegas

GLOBALSHOP 2017

MARCH 28 - 30 2017

MANDALAY BAY - BAYSIDE C-E

LAS VEGAS, NV



Booth Legend	
	Available
	Reserved
	Assigned

FIRE AND SAFETY LEGEND	
	EGRESS ASBLE PER CCDD APPROVED MASTER EXIT PLAN. SEE GENERAL NOTES.
	PRE-FUNCTION SPACE PER CCDD APPROVED MASTER EXIT PLAN. SEE GENERAL NOTES FOR DESCRIPTION.
	REFUGER AREA PER CCDD APPROVED MASTER EXIT PLAN. SEE GENERAL NOTES FOR DESCRIPTION.
1. MASTER EXIT PLAN GENERAL NOTES: 2. THE PURPOSE OF THIS DRAWING IS TO OUTLINE THE BOUNDARIES OF THE PRE-FUNCTION AREA AND REQUIRED REFUGER AREA BASED ON CLARK COUNTY FIRE DEPARTMENT INSPECTION REQUIREMENTS. 3. ALL OCCUPANT LOAD FACTORS AND OCCUPANT LOADS ARE BASED ON PREVIOUSLY APPROVED CORP DRAWINGS. 4. PRE-FUNCTION AREAS WILL BE PROVIDED WITH TABLES, CHAIRS, BOOTHS, ETC. SPECIFIC ARRANGEMENT WILL VARY BY EVENT. BOUNDARIES DEPICTED ON DRAWING DO NOT REPRESENT PHYSICAL SEPARATIONS. BOUNDARIES REPRESENTED HEREIN ARE TO BE UTILIZED AS A GUIDE FOR CCDD INSPECTORS.	
FHC	- FIRE HOSE CABINET
FE	- FIRE EXTINGUISHER CABINET
FS	FIRE STROBE
MUST MAINTAIN AT LEAST 36" OF ACCESS AROUND ALL FIRE EQUIPMENT PER CCDD.	